



Ron Chapman, MD, MPH
Director & State Health Officer

State of California—Health and Human Services Agency
California Department of Public Health

DRINKING WATER FIELD OPERATIONS BRANCH

50 D STREET, SUITE 200, SANTA ROSA, CA 95404

PHONE: (707) 576-2145 / FAX: (707) 576-2722

INTERNET ADDRESS: www.cdph.ca.gov



EDMUND G. BROWN JR.
Governor

May 8, 2014

Water System No. 4900637

Julia Parmeter
Magic Mountain Mutual Water Company
P.O. Box 566
Monte Rio, CA 95462

CITATION NO. 02-18-14C-013

**TOTAL COLIFORM MAXIMUM CONTAMINANT LEVEL (MCL) VIOLATION FOR
MARCH 2014**

Enclosed is a Citation issued to the Magic Mountain Mutual Water Company (System) public water system.

Your System will be billed at the Department's hourly rate (currently estimated at \$126.00) for the time spent on issuing this Citation since this is an enforcement action for noncompliance with State regulations. At this time, we have spent approximately one hour on enforcement activities associated with this violation. You will receive a bill sent from our Fee Billing Unit in Sacramento on approximately August 1, 2014. This bill will contain fees for any enforcement time spent on your System.

If you have any questions regarding this matter, please contact Cindi Lee of my staff at (707) 576-2422 or me at (707) 576-2006.

Sincerely,

Janice M. Thomas, P.E.
Sonoma District Engineer
Drinking Water Program

Enclosures

STATE OF CALIFORNIA
DEPARTMENT OF PUBLIC HEALTH

Name of Public Water System: Magic Mountain Mutual Water Company

Water System No: 4900637

To: Magic Mountain Mutual Water Company
P.O. Box 566
Monte Rio, CA 95462

Issued: May 8, 2014

CITATION FOR NONCOMPLIANCE

With Total Coliform Maximum Contaminant Level for March 2014

Section 116650 of the California Health and Safety Code (CHSC), authorizes the issuance of a citation for failure to comply with a requirement of California Safe Drinking Water Act (CHSC, Division 104, Part 12, Chapter 4, commencing with Section 116270), or any regulation, standard, permit or order issued thereunder.

The Division of Drinking Water and Environmental Management of the State of California Department of Public Health (Department) hereby issues a citation to the Magic Mountain Mutual Water Company (System) for failure to comply with Title 22, California Code of Regulations (CCR) Section 64426.1.



APPLICABLE AUTHORITIES

Section 116650 of the CHSC states in relevant part:

- (a) If the department determines that a public water system is in violation of this chapter or any regulation, permit, standard, citation, or order issued or adopted thereunder, the department may issue a citation to the public water system. The citation shall be served upon the public water system personally or by certified mail. Service shall be deemed effective as of the date of personal service or the date of receipt of the certified mail. If a person to whom a citation is directed refuses to accept delivery of the certified mail, the date of service shall be deemed to be the date of mailing.
- (b) Each citation shall be in writing and shall describe the nature of the violation or violations, including a reference to the statutory provision, standard, order, citation, permit, or regulation alleged to have been violated.
- (c) A citation may specify a date for elimination or correction of the condition constituting the violation.
- (d) A citation may include the assessment of a penalty as specified in subdivision (e).
- (e) The department may assess a penalty in an amount not to exceed one thousand dollars (\$1,000) per day for each day that a violation occurred, and for each day that a violation continues to occur. A separate penalty may be assessed for each violation.



1 California Code of Regulations (CCR), Section 64426.1 states in relevant
2 part:

3
4 (b) A public water system is in violation of the total coliform MCL {maximum
5 contaminant level} when any of the following occurs:

- 6 (1) For a public water system which collects at least 40 samples per
7 month, more than 5.0 percent of the samples collected during any
8 month are total coliform-positive; or
9 (2) For a public water system which collects fewer than 40 samples per
10 month, more than one sample collected during any month is total
11 coliform-positive; or
12 (3) Any repeat sample is fecal coliform-positive or E. coli-positive; or
13 (4) Any repeat sample following a fecal coliform-positive or E. coli-positive
14 routine sample is total coliform-positive.

15
16 **STATEMENT OF FACTS**

17
18 The Department has received laboratory results for twenty-one
19 bacteriological samples collected during March 2014 from the System. All
20 samples were analyzed for the presence of coliform bacteria. Three of the
21 twenty-one samples tested positive for coliform bacteria.
22

23
24 **DETERMINATIONS**

25
26 **THE DEPARTMENT HAS DETERMINED:**
27



1 The System violated Title 22 of the CCR, Section 64426.1, in that the
2 System failed to comply with the maximum contaminant level (MCL) for total
3 coliform bacteria during the month of March 2014.

4
5 **DIRECTIVES**
6

7
8 Magic Mountain Mutual Water Company is hereby directed to take the
9 following actions:

- 10
11 1. Comply with Section 64426.1, Title 22, of the California Code of
12 Regulations in all future monitoring periods.
13
14
15 2. Notify all persons served by the System of the MCL violation in
16 conformance with Section 64463.4 and 64465, Title 22 of the CCR,
17 and as follows:
18
19 a) Completion of Attachment A to include the name, address, and
20 telephone number of a System representative as a source of
21 additional information concerning the public notice. **You must**
22 **also give a legible, written description (preferably typed) of**
23 **the corrective actions taken by the water system to prevent**
24 **this violation from occurring in the future. You must use the**
25 **space provided in Attachment A for this written description.**
26
27



1 b) Provide the notice by mail or direct delivery, **after it has been**
2 **completed in accordance with (a) above**, to each customer or
3 service connection served by the System by **June 10, 2014**.

4
5 c) Provide public notice for this violation in accordance with Section
6 64465(c), Title 22 or the CCR, which requires for each non-
7 English speaking group that exceeds 1,000 residents or 10% of
8 the residents in a community (whichever is less) that the public
9 notice contain information in the appropriate language(s)
10 regarding the importance of the notice, or contain a telephone
11 number or address where such residents may contact the water
12 system to receive a translated copy of the notice or to receive
13 assistance in the appropriate language.
14
15

16
17 3. The System shall complete the attached Compliance Certification
18 form and return it to the Department within 10 days of the public
19 notice being given to the system customers but in no case later than
20 **June 16, 2014. A copy of the notice delivered to the customers**
21 **must be attached to the form.**
22

23
24 The Department reserves the right to make such modifications to this
25 Citation, as it may deem necessary to protect public health and safety.
26 Such modifications may be issued as amendments to this Citation and shall
27 be effective upon issuance.



1 Nothing in this Citation relieves the System of its obligation to meet the
2 requirements of the California Safe Drinking Water Act (CHSC, Division 104,
3 Part 12, Chapter 4, commencing with Section 116270), or any regulation,
4 standard, permit or order issued thereunder.

5
6 All submittals required by this Citation shall be submitted to the Department
7
8 at the following address: Janice M. Thomas, P.E.
9 Department of Public Health
10 Drinking Water Program
11 50 D Street, Suite 200
12 Santa Rosa, CA 95404

13 **PARTIES BOUND**

14
15 This Citation shall apply to and be binding upon the System, its officers,
16 directors, agents, employees, contractors, successors, and assignees.

17 **SEVERABILITY**

18
19
20 The directives of this Citation are severable, and the System shall comply
21 with each provision thereof notwithstanding the effectiveness of any
22 provision.

23 **FURTHER ENFORCEMENT ACTION**

24
25
26
27 Division 104, Part 12, Chapter 4, (commencing with Section 116270) of the
California Health and Safety Code authorizes the Department to: issue



1 additional citations with assessment of penalties if the System continues to
2 fail to correct a violation identified in a citation; take action to suspend or
3 revoke a permit that has been issued to a public water system if the System
4 has violated applicable law or regulations or has failed to comply with orders
5 of the Department; and petition the superior court to take various
6 enforcement measures against a public water system that has failed to
7 comply with orders of the Department. The Department does not waive any
8 further enforcement action by issuance of this citation.
9

10
11
12 Janice M. Thomas

13 Janice M. Thomas, P.E.
14 Sonoma District Engineer
15 Drinking Water Program
16

April 8, 2014

Date



17 Attachments

18 Certified Mail No 70101870000059270144
19
20
21
22
23
24
25
26
27



1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27

COMPLIANCE CERTIFICATION

Citation Number 02-18-14C-013

Name of Water System: **Magic Mountain Mutual Water Company**

System Number: 4900637

Certification

I certify that the users of the water supplied by this water system were notified of the bacteriological violations of Title 22, California Code of Regulations (CCR) for the compliance period of March 2014.

Required Action

Date Completed

Complete Attachment A, as required in Directive 2(a)

Public Notification – Mail or Direct Delivery to Customers

Signature of Water System Representative

Date

Attach a copy of the notice delivered to customers.

THIS FORM MUST BE COMPLETED AND RETURNED TO THE DEPARTMENT NO LATER THAN JUNE 16, 2014

Disclosure: Be advised that Section 116725 and 116730 of the California Health and Safety Code states that any person who knowingly makes any false statement on any report or document submitted for the purpose of compliance with the attached order may be liable for a civil penalty not to exceed five thousand dollars (\$5,000) for each separate violation for each day that violation continues. In addition, the violators may be prosecuted in criminal court and upon conviction, be punished by a fine of not more than \$25,000 for each day of violation, or be imprisoned in county jail not to exceed one year, or by both the fine and imprisonment.



IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER

Este informe contiene información muy importante sobre su agua potable. Tradúzcalo o hable con alguien que lo entienda bien.

Magic Mountain Mutual Water Company Had Levels of Coliform Bacteria Above the Drinking Water Standard During March 2014

Our water system recently violated a drinking water standard. Although this is not an emergency, as our customers, you have a right to know what happened, what you should do, and what we did to correct the situation. Please share this information with other people who drink this water, especially those who may not have received this notice directly. You can do this by posting this notice in a public place or giving out copies by hand or mail.

What happened? We routinely monitor our drinking water for contaminants. We took 21 water samples to test for the presence of coliform bacteria during March 2014. Three of our samples showed the presence of coliform bacteria. The standard is that no more than one sample per month may test positive for bacteria. The positive samples were tested further for fecal coliform. **No fecal coliform or E. coli were found.** However, our drinking water exceeded the maximum contaminant level allowed for total coliform bacteria, as specified in Section 64426.1, Title 22 of the California Code of Regulations (CCR).

What does this mean? The California Department of Public Health (Department) sets drinking water standards and has determined that the presence of total coliform bacteria is a possible health concern. Coliforms are bacteria that are naturally present in the environment and are used as an indicator that other, potentially harmful, bacteria may be present. Coliforms were found in more drinking water samples than allowed. This was a warning of potential problems and a violation of the regulations.

What should I do? You do not need to boil your water or take other corrective actions. This is not an emergency. If it had been, you would have been notified immediately.

People with severely compromised immune systems, infants, and some elderly may be at increased risk. These people should seek advice about drinking water from their health care providers. General guidelines on ways to lessen the risk of infection by microbes are available from EPA's Safe Drinking Water Hotline at (800) 426-4791.

If you have other health concerns related to the consumption of this water, you may wish to consult your doctor.

Has the problem been resolved? What corrective actions have been taken to prevent this violation from occurring in the future?

This notification of the public is being done in compliance with Section 64463.4, Title 22 of the CCR as a means of keeping the public informed.

Persons wishing more information should contact:

(name)

(address)

(phone number)

To all School Administrators, Rental Property Owners, and Business Property Owners:

You must provide public notification within 10 days of the receipt of this notice from **Magic Mountain Mutual Water Company** [Health and Safety Code Section 116450(g)]. The notification must be provided as follows:

SCHOOLS: Must give written notification to school employees, students, and parents (if the students are minors).

RESIDENTIAL RENTAL PROPERTY OWNERS OR MANAGERS (including but not limited to apartment complexes, nursing home facilities, other care facilities): Must give written notification to tenants/patients. Must give written notification to employees (if applicable).

BUSINESS PROPERTY OWNERS, MANAGERS, OR OPERATORS (including but not limited to restaurants, stores, hospitals, churches, clubs, daycare facilities, offices, other businesses): Must give written notification to employees and members. Must post in conspicuous places for customers/visitors (if applicable).